

CORPORATION OF THE DISTRICT OF BURNABY

BY-LAW NO. 1514.



A BY-LAW to amend the "Burnaby Electrical Inspection By-law 1928".

THE COMMISSIONER for the Corporation of the District of Burnaby ENACTS as follows:

1. Sub-section 3 of Section 37 of the "Burnaby Electrical Inspection By-law 1928" being By-law No. 761 of the Corporation is hereby amended by striking out the words "Exception to this rule may be taken when a service supplies only one meter." and substituting therefor the words "Except in installations when the service is alternating current not exceeding 300 Volts between conductors; and the service box or other approved service equipment is not rated at more than 100 amperes; the meter shall be installed with an approved metal fitting in which all live parts and wiring are entirely enclosed therein, upon the line or supply side of such service box or other approved service equipment."

2. This By-law may be cited as "BURNABY ELECTRICAL INSPECTION BY-LAW 1928 AMENDMENT BY-LAW 1935".,

DONE AND PASSED this Fifth (5th) day of June, A.D. 1935.

RECONSIDERED and FINALLY PASSED this Twelfth (12th) day of June, A.D. 1935.



Hugh W. Fraser
COMMISSIONER.

Charles B Brown
CLERK.

I, Charles B Brown, Clerk of the Corporation of the District of Burnaby do hereby certify the foregoing to be a true copy of a by-law passed by the Commissioner for the Corporation of the District of Burnaby on the 12th day of June, A.D. 1935.

Charles B Brown
Clerk.