

THE CORPORATION OF THE DISTRICT OF BURNABY

BY-LAW NO. 6584

A BY-LAW to amend By-Law No. 5096, being the
"Burnaby Fire Prevention By-Law 1968"

The Council of The Corporation of the District of Burnaby
ENACTS as follows:

1. This By-law may be cited as "BURNABY FIRE PREVENTION BY-LAW 1968, AMENDMENT BY-LAW NO. 1, 1975".

2. Article 2.3.11.9. of By-Law No. 5096 is repealed and the following substituted therefor:

"2.3.11.9.(1) The installation and use of coin-operated dispensing apparatus for Class A flammable liquids is prohibited.

(2) A self-service station may be operated provided it meets the following requirements:

(a) Self-service fuel dispensing apparatus at a self-service station shall be under the control of the licensed operator of the self-service station or a competent employee of such licensed operator at all times when the self-service fuel dispensing apparatus is dispensing fuel.

(b) The licensed operator of a self-service station or a competent employee of such licensed operator shall have a control panel for each self-service fuel dispensing apparatus and the licensed operator or a competent employee of such licensed operator shall be at the said control panel when fuel is being dispensed from a self-service fuel dispensing apparatus.

(c) The licensed operator or a competent employee of such licensed operator must, when at the control panel, be able to see all the self-service fuel dispensing apparatus so that such licensed operator

or a competent employee of such licensed operator may, in case of fire or other emergency, stop fuel being dispensed from all self-service fuel dispensing apparatus simultaneously.

- (d) Every self-service fuel dispensing apparatus shall be installed so that no fuel may be dispensed until the control panel has been set by the licensed operator or a competent employee of such licensed operator.
- (e) The nozzle of a self-service fuel dispensing apparatus shall close automatically and not dispense fuel when the hand of the operator is removed from the nozzle control lever.
- (f) No nozzle of a self-service fuel dispensing apparatus shall have a latch-open device.
- (g) Each control panel shall control not more than twelve self-service fuel dispensing apparatus.
- (h) A self-service station shall have an intercommunication system so that the licensed operator of a self-service station or a competent employee of such licensed operator may communicate with the operator of the self-service fuel dispensing apparatus.
- (i) Every self-service station shall have a 10 lb. class ABC all purpose fire extinguisher for each 2 or more self-service dispensing apparatus located on an island.
- (j) Every self-service station shall have a 10 lb. class ABC all purpose fire extinguisher located at the control panel.

- (k) Every self-service station shall have sufficient metal containers for the storage of all combustible waste. No cardboard or plastic containers shall be used for this purpose.
- (l) Every licensed operator of a self-service station shall, before installing or replacing any fuel dispensing apparatus or tanks, submit plans and specifications for same to the Fire Chief and obtain from the Fire Chief a permit for such installation or replacement.
- (m) Every operator of a self-service fuel dispensing apparatus on a self-service station shall before dispensing fuel to his motor vehicle, shut off the motor of said motor vehicle.
- (n) No person shall smoke a cigarette, cigar, pipe or any other matter or thing within 20 feet of a motor vehicle when such motor vehicle is being supplied fuel from a self-service fuel dispensing apparatus of a self-service station.
- (o) A sign visible to the operator of a self-service fuel dispensing apparatus on a self-service station shall be installed by the licensed operator of such self-service station, which said sign shall read as follows:
- "No Smoking - shut off motor while dispensing fuel. Articles 2.3.11.9.(2) (m) and (n) By-Law No. 5096, being the 'Burnaby Fire Prevention By-Law 1968'."
- (p) A self-service fuel dispensing apparatus at a self-service station shall be located at least

15 feet from any self-service station property line."

3. Article 2.3.11.11.(3) of By-Law No. 5096 is repealed and the following substituted therefor:

"2.3.11.11.(3) Except as provided in Article 2.3.11.9., no person other than the licensed operator of a service station or a competent employee of such licensed operator shall dispense a flammable or combustible liquid into the fuel tank of a motor vehicle."

4. Article 2.3.11.11. of By-Law No. 5096 is amended by adding the following as clause (4):

"2.3.11.11.(4) A sign visible to the operator of a fuel dispensing apparatus on a service station shall be installed by the licensed operator of such service station, which said sign shall read as follows:

No person other than the licensed operator or a competent employee of such licensed operator shall dispense a flammable or combustible liquid into the fuel tank of a motor vehicle. Article 2.3.11.11.(3) By-Law No. 5096, being the "Burnaby Fire Prevention By-Law 1968". "

Read a first time this 13th day of January, 1975.

Read a second time this 13th day of January, 1975.

Read a third time this 13th day of January, 1975.

Reconsidered and adopted this 20th day of January,

1975.



A handwritten signature in cursive script, likely belonging to the Mayor, is written over a horizontal line.

M A Y O R

A handwritten signature in cursive script, likely belonging to the Clerk, is written over a horizontal line.

C L E R K