

THE CORPORATION OF THE DISTRICT OF BURNABY

BY-LAW NO. 6795

A BY-LAW to amend By-Law No. 6335, being the  
"Burnaby Plumbing By-Law 1973".

The Council of The Corporation of the District of  
Burnaby ENACTS as follows:

1. This By-law may be cited as "BURNABY PLUMBING BY-LAW  
1973, AMENDMENT BY-LAW NO. 4, 1975".

2. Subsection (2) of section 27 of By-Law No. 6335 is  
repealed and the following substituted therefor:

"(2) (a) There shall be no direct connection between any  
domestic water supply line and any circulating pump, filter,  
water softener, or other apparatus, or device that comes in  
contact with the water in or from the pool. Recirculating  
systems shall take the water supply to the pool from an open  
surge tank or other approved system. The supply to the surge  
tank shall be above the extreme overflow level in such manner  
as to prevent water from the tank entering the supply line.

(b) When a combined or sanitary sewer is available  
for use, swimming pool waste water shall be discharged there-  
into after a permit has been obtained from the proper authority  
to do so. The rate of discharge shall be limited to a maximum  
rate of 120 gallons per minute from residential pools and a  
maximum of 250 gallons per minute from commercial pools.

(c) Swimming pool waste water may not be used for  
surface or sub-surface irrigation.

(d) Swimming pools shall have the bottom and inner  
sides constructed of smooth non-absorbent materials and be so  
constructed as to be properly drained through one or more metal  
grated openings.

(e) All swimming pool drain lines shall discharge to a 24 inch diameter sump that is properly connected to a combined or sanitary sewer. If the sump is subject to back-flow of sewage a backwater valve shall be installed.

(f) Scum gutter drains and/or floor drains serving the walks around the pool may be installed as a special drain pipe and shall discharge directly to a 24 inch diameter sump. The special drain pipe shall be trapped with a bend installed in the sump below the water level.

(g) A swimming pool installation with a separation tank for the cleaning and collecting of waste material from swimming pool waste water will be permitted subject to the separation tank being of an engineered design and installed in accordance with the manufacturers' recommendations.

Read a first time this 29th day of December, 1975.

Read a second time this 29th day of December, 1975.

Read a third time this 29th day of December, 1975.

Reconsidered and adopted this 12th day of January, 1976.



A handwritten signature in black ink, appearing to be "Donald B. Young".

M A Y O R

A handwritten signature in black ink, appearing to be "John J. ...".

DEPUTY

C L E R K