

BURNABY FIRE DEPARTMENT  
MONTHLY REPORT

FEBRUARY, 1970

TO: Mr. H.W. Balfour,  
Municipal Manager,

ALARMS (Type)	No.	Loss	No. to-date	Loss to-date
BUILDING	21	\$ 44,292	44	\$ 157,162
CHIMNEY	1		9	
OIL BURNER	3		7	
VEHICLE	9	881	19	6,206
MISCELLANEOUS	3	160	5	160
RUBBISH	8		17	
RESCUE & SAFETY	40		95	
NEEDLESS	11		19	
ACCIDENTAL	8		19	
PUBLIC SERVICE	22		43	
FALSE ALARMS	2		5	
BUSH & GRASS	6		6	
TOTALS...	134	\$ 45,333	288	\$ 163,528

FIRES & LOSSES  
BY OCCUPANCY

A 6 Schools			1	100
B 3 Nursing & Rest H.	2	1,250	4	1,480
C 1 Apartments	1	700	3	108,700
C 2 Hotels-Motels			1	100
C 5 Pvt. Dwellings	10	8,342	16	10,702
D 3 Offices			1	2,000
D 4 Restaurants			1	80
F 5 Paints & Plastics	1	34,000	1	34,000
F 20 Repair Shop	1	160	1	160
Vehicles	4	881	10	6,206
TOTALS...	19	\$ 45,333	39	\$ 163,528

FIRE CAUSE & LOSS

Defective Chimneys			2	97,000
Sparks on roofs	1	41	1	41
Defective Stoves	1	1,000	2	1,170
Combustibles nr. Stove	1	4,800	1	4,800
Open Lights, flames	1	700	1	700
Careless smoking	4	576	9	4,166
Children with matches	3	1,775	3	1,775
Careless use/matches	-	.	1	80
Electric appl. motors	-	.	1	200
Use /inflammables	2	35,200	3	46,700
Grease on stove			1	80
Spontaneous ignition	1	200	1	200
Miscellaneous Known	1	160	2	310
Suspicious			1	100
Vehicles	4	881	10	6,206
TOTALS...	19	\$ 45,333	39	\$ 163,528

MONTHLY REPORT - Page 2

February, 1970

<u>OCCUPANCY OF BUILDINGS</u>	<u>Bureau Inspections</u>	<u>Company Inspections</u>
ASSEMBLY	33	
INSTITUTIONAL	16	5
RESIDENTIAL	46	
BUSINESS & PERSONAL SERVICES	47	15
MERCANTILE	22	
COMMERCE & INDUSTRIAL	90	17
<u>INSPECTIONS &amp; INVESTIGATIONS</u>		
FIRE HAZARDS	3	
COMPLAINTS	15	
FIRE INVESTIGATIONS	34	13
GAS TANK & PUMP INSPECTIONS	15	
COMPRESSED GAS INSPECTIONS	13	
RE-INSPECTIONS	63	
LICENCE INSPECTIONS	63	
COURT APPEARANCES	1	
STUMP PILES	8	
INSPECTIONS AT S.F.U.	7	
BUILDING PLANS	22	
LECTURES & DEMONSTRATIONS	5	
MISCELLANEOUS	28	5
TOTALS...	<u>531</u>	<u>55</u>
<u>FELS COLLECTED</u>	<u>Permits</u>	<u>Amount</u>
Gas Tank & Pumps	5	\$ 18.00
Compressed Gas	6	15.00
TOTALS...	<u>11</u>	<u>33.00</u>

REMARKS:

A fire loss of \$34,000.00, February 4, 1970, at 6848 Jubilee Avenue, accounted for the major portion of the total fire loss during the month. The fire was caused by careless dispensing of flammable liquids. Vapors were ignited by oil fired furnace and flashed back to spillage igniting wooden structure and other flammable materials inside the wooden portion of the building.

Respectfully submitted.

L.C. Auvache,  
Chief of Fire Department  
*G. Monk*  
Per: G. Monk.