

8. Re: Street Lighting Changes

Following for Council's approval is a request from the Municipal Engineer concerning street lighting changes on Moscrop Street.

RECOMMENDATION:

THAT the Municipal Engineer's request be approved.

* * * * *

Engineering Department

6 April 1972

Mr. M. J. Shelley
MUNICIPAL MANAGER

Dear Sir:

We request Council approval for the following street lighting changes on Moscrop Street between Boundary and Huxley Avenues which are recommended as a result of Council's request for upgrading:

Existing 9 lamps be changed from 300 Watt Mercury Vapour to 450 Watt Mercury Vapour;

10 new 450 Watt Mercury Vapour Luminaires.

Additional Information:

The lights are to be installed at regular intervals along the route according to a plan prepared by the B. C. Hydro and is based on criteria of the Canadian Standards Association and the Illuminating Engineering Society.

There will be no installation costs to Burnaby because the additional revenue to Hydro and the salvage will offset these costs. However, the power cost per month will be increased from \$40.35 to \$103.00 resulting in an annual increased cost of \$751.80.

Respectfully submitted,

E. E. Olson

E. E. Olson
MUNICIPAL ENGINEER

/dm