

ITEM 23

MANAGER'S REPORT NO. 9

COUNCIL MEETING Feb. 5/73


23. Re: Letter from Mr. Eric W. Miles, 6954 E. Broadway
Request for Sanitary Sewer

Appearing on the Agenda for the February 5, 1973 meeting of Council is an undated letter from Mr. Eric W. Miles addressed to the Engineer with a carbon copy to Council. Mr. Miles and four petitioners request installation of a sanitary sewer line to their properties on East Broadway.

The Engineer on January 31, 1973, notified the petitioners in writing that it is not economically feasible to serve the five parcels (see shaded areas on the attached sketch) with a sanitary sewer as requested. As shown on the sketch, the nearest sanitary sewer outlet is at Kingsford and Kneale Place, approximately 1000 feet away. Serving of the properties would require extensive easement requirements and "doglegging" of the main to utilize the outlet. The estimated total cost of serving the five parcels would be approximately \$20,000 or a prohibitive \$4,000 per connection.

This is for the information of Council.

ITEM 23
 MANAGER'S REPORT NO. 9
 COUNCIL MEETING Feb. 5/73



----- EXISTING LINE
 EXTENSION REQUIREMENTS
 NOTE: The five subject parcels are shaded in the sketch above.