

ITEM 10
MANAGER'S REPORT NO. 58
COUNCIL MEETING Sept. 15/75

Re: STORM SEWER ON JUBILEE AVENUE
LETTER FROM MRS. K.F. AIKENHEAD THAT APPEARED ON THE
AGENDA FOR THE SEPTEMBER 8, 1975 MEETING OF COUNCIL (Item L)

On September 8, 1975, Council received a letter from Mrs. K.F. Aikenhead in regard to a new storm sewer installation that is responsible for flooding and damage to lawns on Jubilee Avenue. Following is a report from the Municipal Engineer on this matter.

RECOMMENDATIONS:

1. THAT action be taken to correct the run-off of water to the sidewalk; and
2. THAT no corrective action be taken with respect to lawns; and
3. THAT a copy of this report be sent to Mrs. K.F. Aikenhead.

* * * * *

11 September, 1975


TO: MUNICIPAL MANAGER
FROM: MUNICIPAL ENGINEER
SUBJECT: JUBILEE AVENUE STORM SEWER

The material used to fill the ditches has gradually settled and compacted leaving grooves, which in spots carry water to the sidewalk. It is a simple matter to correct and will be attended to.

The damage to lawns is on the boulevard portion, and it is our opinion that the grass is growing and nothing more should be done.

RECOMMENDATION:

THAT since the damage to lawns on the boulevard is minimal nothing more be done.


MUNICIPAL ENGINEER

GCM:cmg