

ITEM 7  
MANAGER'S REPORT NO. 59  
COUNCIL MEETING Sept. 22/75

Re: ENGINEER'S SPECIAL ESTIMATES

Following for your approval is the Municipal Engineer's report covering Special Estimates of Work in the total amount of \$249,000.00.

RECOMMENDATION:

1. THAT the estimates be approved as submitted.

\* \* \* \* \*

18 September, 1975

TO: MUNICIPAL MANAGER

FROM: MUNICIPAL ENGINEER

SUBJECT: SPECIAL ESTIMATES

I wish to submit the following special estimates for your consideration.

Work Order No.

22-162	Install new watermains in advance of L.I. Programs as recommended in G.V.W.D. water report - Cambridge - Lane E. of Delta to Beta Union St. - Boundary to McDonald -1600' Lane St. - Royal Oak to Kingsway -1760' Jubilee Avenue - Watling to Imperial -1880' CHARGE: New Mains (20-02) \$151,000.00 ADDITIONAL INFORMATION: These watermain renewals are required in advance of Local Improvement Programs as recommended in G.V.W.D. report.
22-163	Carleton - Kincaid to Forest - Upgrade existing watermain to provide service to Burnaby General Hospital. CHARGE: New Mains (20-02) 6,500.00 ADDITIONAL INFORMATION: This watermain renewal required as recommended in G.V.W.D. report.
22-165	Maywood at McKay and at Silver - Replace sub-standard 4" diameter watermain sections with 8" diameter mains at McKay and Silver. CHARGE: Main Renewals (90-01) 5,000.00 ADDITIONAL INFORMATION: There are two sections of substandard 4" diameter watermain on Maywood at McKay and Silver. These sections connect presently "loop" 8" diameter mains on Maywood, McKay and Silver. Maywood is the subject of a 1975 Local Improvement. The Engineering Department would like to replace these substandard sections prior to the completion of the Local Improvement works.

TOTAL \$162,500.00

  
MUNICIPAL ENGINEER

/cmr