

TO: CITY MANAGER

DATE: 2000 AUG 22

FROM: DIRECTOR ENGINEERING

FILE: 10-01-12

SUBJECT: WORK ORDER:

60-30-105 Sanitary Sewer Renewal - Central Valley

PURPOSE: To obtain approval of Work Order 60-30-105

RECOMMENDATION:


1. THAT the above work order as more specifically referred to in this report, be approved.

REPORT

60-30-105 Sanitary Sewer Renewal - Central Valley

Charge: 2000 Capital Budget
Sanitary Sewer Utility \$150,000

Additional Information: Sanitary sewers in the Central valley area were originally installed on pile supports due to the surrounding poor soil condition. Settlement of the surrounding ground over time leads to failure of the pile caps and blockages to the sewer line. The section between Westminster Ave and Beta, next to the Freeway, has recently failed and requires immediate replacement. Service is being maintained by emergency pumping equipment until repairs are completed at a total estimated cost of \$150,000. These expenditures are not included in the 2000 Capital Program. However, sufficient General Revenue funds are available in the sewer utility and due to the emergency nature of this project, it is recommended that \$150,000 of additional expenditures be approved as an increase to the 2000 Capital Program


DIRECTOR ENGINEERING

AAS:
cc: Director Finance