

TO: CITY MANAGER

DATE: 2004 OCT. 13

FROM: DIRECTOR ENGINEERING

FILE: 32000-05

SUBJECT: WORK ORDER:
60- 21- 144 Kingsgate Pump Station Upgrade

PURPOSE: To obtain approval of Work Order 60-21-144

RECOMMENDATION:

- 1. **THAT** the above work order as more specifically referred to in this report, be approved.

R E P O R T

60-21-144 Kingsgate Pump Station Upgrade

Charge: 2004 Capital Budget
Watermains, pumping stations, etc \$200,000

Additional Information: The City has recently experienced difficulty with one of the two standby emergency power units at the Kingsgate Pump Station. As the Kingsgate Pump Station is the sole source of water supply to SFU, it is important that we expedite replacement of the defective unit and restore full functionality to the pump station. Total replacement cost is estimated at \$200,000. These expenditures are not included in the current year's capital program, however, sufficient General Revenue funds are available in the Water Utility and appropriate adjustments will be made to ensure Capital Budget spending limits are not exceeded.


W.C. Sinclair, P. Eng.
DIRECTOR ENGINEERING

cc: Director Finance